

## Cycle Timer - Percentage Cycle Time Switch

Item CT2000



### PRODUCT DESCRIPTION

The CT2000 Percentage Cycle Time Switch is a field adjustable timer, offering true flexibility for repetitive cycle times via an upfront control button. The timer provides repetitive cycling for short-cycle applications. The timer enclosure includes two slotted mounting holes on 5" centers and a ½" knockout for conduit connection.

### FEATURES

- ▶ Provides 8 field-selectable cycle durations of 30 seconds, 1, 3, 5, 10, 30 minutes and 1 or 4 hours
- ▶ Front cover button enables true flexibility for repetitive cycle times
- ▶ Temporary and permanent manual overrides
- ▶ 30 separate positions enable precise percentage ON time selection
- ▶ User settings stored in non-volatile memory
- ▶ No DIP switches to program cycle time
- ▶ Type 3R indoor/outdoor aluminum enclosure

### APPLICATIONS

- ▶ Agriculture Feeders
- ▶ Greenhouse Misting Control

### TECHNICAL DATA

General	
Model Number	CT2000
Description	Percentage Cycle Time Switch
UPC Code	078275124363
Brand	Intermatic
Country of Origin (Intermatic)	MEXICO
Warranty Period	1-Year limited
Control Specifications	
Cycle Duration	30 sec; 1 min; 3 min; 5 min; 10 min; 30 min; 1-Hour; 4 hours
Mechanical Specifications	
Enclosure Type	Outdoor type 3R metal
Dimensions	
Product Dimensions (H x W x D) in	6.625 x 3.5 x 3.313 in
Material Specifications	
Color	Gray
Load Ratings	
Pilot Duty (NO) Range(s)	470 VA, 240 VAC
General Purpose (NO) Range(s)	20 A, 240 VAC
Motor Load Ratings NO Ranges	1 HP @ 120 VAC; 2 HP @ 240 VAC
Electrical Specifications	

Wiring Option	Wire leads
Switch Type	SPST

**Packaging**

Shipping Weight (lbs)	1.397
Unit Carton Dimensions (H x W x L) in	4.06 x 4 x 7.38 in

**Environmental Specifications**

Temperature (operation)	-14 °F to 140 °F / (-10 °C to 60 °C)
-------------------------	--------------------------------------

**Standards and Certifications**

CSA Certification	cCSAus
Other Certifications and Compatibilities	Green Energy
California Proposition 65	DEHP
RoHS Certification	N/A